



NOTES

1. CONCRETE GRADE N25.
2. PRECAST CONCRETE COVERS TO BE REINFORCED WITH 6 DIAMETER M.S. RODS AT 100 CENTRES, PLACED LONGITUDINALLY AND TRANSVERSELY; OR SL81 MESH.
3. LOCATION AND LEVEL OF JUNCTION BOX SHOWN IN THE DRAWINGS REFER TO THIS POINT: ●
4. SIDE WALLS OF ALL PITS DEEPER THAN 1500 TO BE REINFORCED WITH ONE LAYER OF RL1218 MESH RETURNED 300 INTO BASE.
5. AT RIGHT ANGLE CHANGE IN PIPE DIRECTION OUTLET INVERT TO BE 150 BELOW INLET INVERT.
6. DEPTH OF JUNCTION BOX NOT TO EXCEED 3500.
7. MINIMUM COVER OF REINFORCEMENT SHALL BE 50 UNLESS SHOWN OTHERWISE.

THIS DRAWING MAY BE PREPARED IN COLOUR AND MAY BE INCOMPLETE IF COPIED

QR CODE SCAN TO CHECK DOCUMENT VER.		REV	DATE	AMENDMENT / REVISION DESCRIPTION	WVR No.	APPROVAL	ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE SHOWN	CONTACT DETAILS SEND FEEDBACK ON THIS STANDARD DRAWING TO : technologystandards@rms.nsw.gov.au	ISSUED SFR MANAGER ROAD POLICY, SPECIFICATIONS & TECHNOLOGY	Transport Roads & Maritime Services	STANDARD DRAWING ROAD DESIGN ENGINEERING R0220 STORMWATER DRAINAGE SERIES - GULLY PITS DRAINAGE JUNCTION BOX SHEET 1 OF 1	A3
							DATE 20.01.17	PREPARED BY ENGINEERING SERVICES ROAD POLICY, SPECIFICATIONS AND AND TECHNOLOGY	STANDARD DRAWING No. R0220-29 STATUS ISSUED EDMS No. DS2014/005849 ORIGINAL ISSUE DATE JANUARY 2017			