



# Test method T275

Average least dimension of aggregate  
(5 mm and 7 mm)

OCTOBER 2012



---

## Revision Summary

Ed/Rev Number	Clause Number	Description of Revision	Authorisation	Date
		Reformatted and Revision Summary Added	D Dash	May 1999
		Date on Test Method Revised to Agree with Date on Revision Summary	D Dash	Feb 2001
Ed 2/ Rev 0	All	New Issue. Reference to AS 1141.20.2.	J Friedrich	June 2010
Ed 3/ Rev 0	All	Reformatted and Revision Summary added	J Friedrich	October 2012

Note that Roads and Maritime Services is hereafter referred to as 'RMS'.

The most recent revision to Test method T275 (other than minor editorial changes) are indicated by a vertical line in the margin as shown here.

---

## Test method T275

### Average least dimension of aggregate (5 mm and 7 mm)

#### 1. Scope

This test method sets out the procedure for determining the average least dimension of aggregate particles of nominal size 5 mm and 7 mm.

#### 2. General

The test is applicable to aggregate particles with nominal size 5 mm and 7 mm.

*NOTE: Use T235 for aggregate particles with nominal size 10 mm and greater.*

#### 3. Apparatus, Preparation, Procedure, Calculations and Reporting

(a) For particles with nominal size 5 mm and 7 mm use AS 1141.20.2 “Methods for sampling and testing aggregates – Average least dimension – Direct measurement (nominal sizes 5 mm and 7 mm)” with the following amendments:

- (i) Replace Clause 4(a) with “Sieve the sample as outlined in AS 1141.11.1 or T201”
- (ii) Include reference to this test method in the report