




**Transport**  
Roads & Maritime  
Services

# Test method T320

Determination of air content of freshly mixed concrete

OCTOBER 2012



---

## Revision Summary

Ed/Rev Number	Clause Number	Description of Revision	Authorisation	Date
		Reformatted and Revision Summary Added	D.Dash	May 1999
		Date on Test Method Revised to Agree with Date on Revision Summary	D.Dash	Feb 2001
Ed 2/ Rev 0	All	Reformatted RMS template	J Friedrich	October 2012

Note that Roads and Maritime Services is hereafter referred to as 'RMS'.

The most recent revision to Test method T320 (other than minor editorial changes) are indicated by a vertical line in the margin as shown here.

# Test method T320

## Determination of air content of freshly mixed concrete

### 1. Scope

This test method sets out the procedure for determination of the air content of freshly mixed concrete from observations of the reduction in air pressure in a chamber above the concrete when the concrete is exposed to the air pressure. It is only applicable for use with concrete made with relatively dense natural aggregates.

### 2. Test Requirements, Procedure and Reporting

The method is identical with the procedure described in Section 2 of AS 1012.4 - Methods for the Determination of Air Content of Freshly Mixed Concrete.